

Attachment L - Results Summary Lead in Water Sample

School Name: Thomas E. Bowe Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S001	39-0612-001	Sink in D135	2.16	No
B001	39-0612-002	Bubbler in Media Office	459	Yes
S002	39-0612-003	Sink in D138	3.56	No
WF001	39-0612-004	WF in Hall outside D144 (left)	ND	No
S003	39-0612-005	Sink D144	5.79	No
S004	39-0612-006	Sink in Media Office	ND	No
S005	39-0612-007	Sink D103	246	Yes
S006	39-0612-008	Sink C105	1.32	No
S007	39-0612-009	Sink in B157	3.61	No
S008	39-0612-010	Sink in Nurses Office	ND	No
IM001	39-0612-011	Ice Machine in Nurse's Office	3.34	No
S009	39-0612-012	Sink Boys Toilet D132	1	No
S010	39-0612-013	Sink Girls Toilet D129	ND	No
WF002	39-0612-014	WF in Hall Near B143 (left)	1.07	No
S011	39-0612-015	Sink B136	ND	No
WF003	39-0612-016	WF in hall near C135 Girl's Restroom	ND	No
S012	39-0612-017	Sink in Girls Toilet C135	1.26	No
S013	39-0612-018	Sink C127	1.17	No
S014	39-0612-019	Sinks Girl Toilet C129	1.22	No
S015	39-0612-020	Sink Boys Toilet C132	1.93	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Thomas E. Bowe Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WF004	39-0612-021	WF in Hall by C132	29	Yes
S016	39-0612-022	Sink in Kitchen	2.77	No
S017	39-0612-023	Sink in Kitchen	1	No
S018	39-0612-024	Sink in Kitchen	ND	No
S019	39-0612-025	Sink in Kitchen	1.02	No
S020	39-0612-026	Sink in Kitchen	ND	No
S021	39-0612-027	Sink in Kitchen Bathroom	2.6	No
S022	39-0612-028	Sink in A109 Faculty Dining Room	2.27	No
S023	39-0612-029	Sink A102 Music Room	4.6	No
B002	39-0612-030	Bubbler A102 Music Room	2.55	No
S024	39-0612-031	Sink A104 Music Room Office	2.99	No
S025	39-0612-032	Sink A105 Music Room Orchestra	3.21	No
S026	39-0612-033	Sink boys Restroom coaches office	2.4	No
WF005	39-0612-034	WF in Hall across from Girl's Locker Room	2.5	No
S027	39-0612-035	Sink C103 Toilet	1.02	No
S028	39-0612-036	Sink C102 Toilet	ND	No
S029	39-0612-037	Sink in Girl's Locker Coach's office	8.02	No
BF001	39-0612-038	WF bottle filler outside C132 & C129	ND	No
BF002	39-0612-039	WF bottle filler in hall near B143	ND	No
WF008	39-0612-040	WF in Media Center Office	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

