

## Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S001	39-0606-001	Sink A101C	1.81	No
WF001	39-0606-002	WF across from A102	ND	No
S002	39-0606-003	Sink E106 A	1.56	No
S003	39-0606-004	Sink E106	36	Yes
S004	39-0606-005	Bathroom Sink Nurse	22	Yes
WF002	39-0606-006	WF across from A106	ND	No
S005	39-0606-007	Sink in Women's Room	ND	No
BF001	39-0606-008	Bottler Filler across from A102	ND	No
S006	39-0606-009	Sink - between Men's & Women's	3.1	No
S007	39-0606-010	Sink A107 (sink closest to door)	9.54	No
S008	39-0607-011	Sink A131 (exterior wall)	31.2	Yes
S009	39-0607-012	Sink A141	15.9	Yes
S010	39-0607-013	Sink A126	ND	No
S011	39-0607-014	Sink A140 A	1.44	No
S012	39-0607-015	Sink A140	9.55	No
S013	39-0607-016	Sink A139A	4.95	No
S014	39-0607-017	Sink A139	1.9	No
S015	39-0607-018	Sink A138 A	2.74	No
S016	39-0607-019	Sink A138	69.4	Yes
S017	39-0607-020	Sink A137	2.74	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S018	39-0607-021	Sink in Women's Faculty Restroom Café	13.3	No
S019	39-0607-022	Sink A132	9.71	No
S020	39-0607-023	Sink Female Faculty Restroom	ND	No
WF004	39-0607-024	WF across from A137	879	Yes
S021	39-0607-025	Sink Women's Faculty Room	1.99	No
S022	39-0607-026	Sinks Women Room	ND	No
WF005	39-0607-027	WF across from A114	ND	No
S023	39-0607-028	Sink A118	4.09	No
WF006	39-0607-029	WF in hall by Boiler Room	ND	No
S024	39-0607-030	Sink A144	6.01	No
S025	39-0607-031	Sink in Backstage Dressing Room (E102B)	58.6	Yes
S026	39-0607-032	Slop Sink in Trainer Room	ND	No
S027	39-0606-033	Sink E105E	4.86	No
WF007	39-0606-034	WF across from B103	104	Yes
S028	39-0606-035	Sink B112C	19.1	Yes
S029	39-0606-036	Sink B106	8.01	No
WF008	39-0606-037	WF in B113	4.86	No
S030	39-0606-038	Sink B117	3.62	No
IM001	39-0606-039	Ice Machine B113A	ND	No
S031	39-0606-040	Sink Girls Room (by B117)	2.46	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WF009	39-0606-041	WF in Hall -near B108	2.01	No
WF010	39-0606-042	WF in Hall - near B109	2.29	No
S032	39-0606-043	Sink B114A	3.94	No
S033	39-0606-044	Sink B114	9.07	No
S034	39-0606-045	Sink C118	1.54	No
IM002	39-0606-046	Ice Machine C118	ND	No
S035	39-0606-047	Sink in C116	6.19	No
S036	39-0606-048	Sink in C115	8.32	No
S037	39-0606-049	Sink C117A	5.41	No
S038	39-0606-050	Sink C102A	12.9	No
S039	39-0606-051	Sink C113	12	No
S040	39-0606-052	Sink C114	4.99	No
WF011	39-0606-053	WF in hall by Weight Room	10.7	No
S041	39-0606-054	Sink Kitchen	35.2	Yes
S042	39-0606-055	Sink Kitchen	40.7	Yes
S043	39-0606-056	Sink Kitchen	3.6	No
S044	39-0606-057	Sink Kitchen	9.27	No
S045	39-0606-058	Sink Kitchen	1.43	No
S046	39-0606-059	Sink Kitchen	2.47	No
S047	39-0606-060	Sink Kitchen	7.76	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
BF002	39-0607-061	Bottle Filler in hall by Boiler Room	ND	No
S048	39-0607-062	Sink Art Room 118	6.34	No
BF003	39-0607-063	Bottler Filler across from A114	ND	No
S049	39-0607-064	Sink Restroom A-wing	ND	No
IM003	39-0606-065	Ice Machine Kitchen	ND	No
WF012	39-0606-066	WF in C102	14.7	No
S050	39-0606-067	Sink C107	7.4	No
S051	39-0606-068	Sink C107	14.8	No
S052	39-0606-069	Sink C107	14.3	No
S053	39-0607-070	Sink Men's Faculty Restroom	ND	No
S054	39-0607-071	Sink Next to Stove ( Concession Stand)	8.07	No
HB001	39-0607-072	Hose Bib by Baseball field	10.8	No
S055	39-0606-073	Sink C107	15.7	Yes
HB002	39-0606-074	Hose Bib - outside A102	92.6	Yes
HB003	39-0606-075	Hose Bib - In Court-yard	7.56	No
HB004	39-0607-076	Hose Bib- outside A145	47.8	Yes
HB005	39-0607-077	Hose Bib - outside A144	539	Yes
HB006	39-0606-078	Hose Bib - C111	ND	No
HB007	39-0606-079	Hose Bib - outside B116	26.2	Yes
S056	39-0606-080	Sink C108	8.66	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
IM004	39-0606-081	Ice Machine (Concession Stand)	ND	No
HB008	39-0606-082	Hose Bib (Concession Stand)	18.3	Yes
WF013	39-0607-083	WF B118	14.8	No
S057	39-0607-084	Sink C108	16.2	Yes
S058	39-0607-085	Sink C112	4.19	No
WF014	39-0607-086	WF by Baseball field (outdoors)	1.42	No
S059	39-0606-087	Sink Vice Principal Bathroom	99	Yes
IM005	39-0606-088	Ice Machine Nurse	3	No
S060	39-0606-089	Sink Men's Restroom	2.48	No
S061	39-0606-090	Sink Men's Faculty Restroom B106	ND	No
S062	39-0606-091	Sink Lady Locker Room Office	48.8	Yes
S063	39-0606-092	E105 Sink	13.1	No
QC BLANK	39-0606-093	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)  
 ND = None Detected; NR = Not Reported