

Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro Intermediate School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S001	39-0608-001	Sink Toilet in Girls locker Room Office	ND	No
S002	39-0608-002	Sink Girls Locker Room Restroom	ND	No
WF001	39-0608-003	WF in Hall near Girls Locker Room	ND	No
S003	39-0608-004	Sink Girls Toilet 111	ND	No
S004	39-0608-005	Sink Work Room 112B	ND	No
WF002	39-0608-006	WF in Hall - outside of 111	1.6	No
S005	39-0608-007	Sink 110 A	NR	No
S006	39-0608-008	Sink 110B	ND	No
S007	39-0608-009	Sink 110A Workroom	3.89	No
S008	39-0608-010	Sink 106 A	1.35	No
S009	39-0608-011	Sink 106B	ND	No
S010	39-0608-012	Sink Faculty Dining	ND	No
S011	39-0608-013	Sink in Nurses Office	6.81	No
S012	39-0608-014	Sink in Music Room	3.18	No
S013	39-0608-015	Sink Boys Toilet	ND	No
WF003	39-0608-016	WF in Hall Outside 104B	1.6	No
S014	39-0608-017	Sink in Kitchen	2.37	No
S015	39-0608-018	Sink in Kitchen (Hand wash)	1.11	No
S016	39-0608-019	Sink in Kitchen (hose in kitchen)	ND	No
S017	39-0608-020	Sink in Kitchen (Dishwash)	1.76	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro Intermediate School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S018	39-0608-021	Sink in Kitchen (Dishwash)	1.68	No
S019	39-0608-022	Sink in Boys Locker Room	ND	No
S020	39-0608-023	Sink in Office restroom in Boys Locker Room	1.68	No
WF010	39-0608-024	WF in hall by Boys Locker Room	ND	No
HB001	39-0608-025	Hose Bib - outside Cafeteria	1.38	No
S021	39-0608-026	Sink Girls Restroom 213A	ND	No
S022	39-0608-027	Restroom Sink in 215	6.48	No
S023	39-0608-028	Sink in 219	11.9	No
WF004	39-0608-029	WF in Hall outside 213	66.8	Yes
S024	39-0608-030	Sink in science room 200	2.22	No
S025	39-0608-031	Sink in science room 201	NR	No
S026	39-0608-032	Sink; Prep Room between Room 200 & 201	3.27	No
S027	39-0608-033	Faculty restroom sink next; by elevator	1.62	No
WF011	39-0608-034	WF in hall by Room 202	6.02	No
WF012	39-0608-035	WF in hall by Room 202	1.02	No
S028	39-0608-036	Boys restroom sink; by Room 202	88.9	Yes
S029	39-0608-037	Girls restroom sink; by Room 202	ND	No
S030	39-0608-038	Sink in Room 202	NR	No
S031	39-0608-039	Sink in Room 309	3.08	No
WF005	39-0608-040	WF in Hall 307	NR	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Glassboro Intermediate School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S032	39-0608-041	Sink in 305	2.13	No
S033	39-0608-042	Sink in toilet - next to 301	ND	No
S034	39-0608-043	Sink B05	77.6	Yes
HB002	39-0608-044	Hose Bib B02	2.94	No
S035	39-0608-045	Sink in PAC1 (ANNEX)	27.1	Yes
S036	39-0608-046	Sink in PAC1 (ANNEX)	67.2	Yes
S037	39-0608-047	Sink in PAC1 (ANNEX)	2.9	No
WF006	39-0608-048	WF in Hall (ANNEX)	1.57	No
S038	39-0608-049	Sink Girl's restroom (ANNEX)	98.3	Yes
S039	39-0608-050	Sink PAC3 (ANNEX)	239	Yes
WF007	39-0608-051	WF in hall 1st floor by Girls Locker Room	ND	No
S040	39-0608-052	Sink in Nurse's Office restroom	ND	No
IM002	39-0608-053	Ice Machine in Nurse	ND	No
WF008	39-0608-054	WF in hall 1st floor by Boys Locker Room	ND	No
S041	39-0608-055	Boys restroom sink (ANNEX)	4.9	No
S042	39-0608-056	Sink in PAC4 (ANNEX)	1.4	No
S043	39-0608-057	Boys restroom sink room 203B	3.57	No
S044	39-0608-058	Restroom sink in teachers room	ND	No
WF009	39-0608-059	WF in hall outside 203B	4.46	No
QC BLANK	39-0608-060	DI Blank	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported