

## Attachment L - Results Summary Lead in Water Sample

School Name: J. Harvey Rodgers School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S001	39-0609-R001	Sink in Kitchen	6.94	No
S002	39-0609-R002	Sink in Kitchen	5.00	No
S003	39-0609-R003	Sink in Kitchen	5.78	No
S004	39-0609-R004	Sink in Kitchen	4.74	No
S005	39-0609-R005	Bathroom Sink in B-4A	6.18	No
S006	39-0609-R006	Bathroom Sink in B-4B	7.15	No
S007	39-0609-R007	Sink in B-4	5.38	No
B001	39-0609-R008	Bubbler in B-4	3.30	No
S008	39-0609-R009	Nurse Bathroom Sink	3.10	No
S009	39-0609-R010	Sink B-3A bathroom	17.80	Yes
S010	39-0609-R011	Sink B-3B bathroom	28.20	Yes
S011	39-0609-R012	Sink B-3	5.34	No
B002	39-0609-R013	Bubbler B-3	0.00	No
S012	39-0609-R014	Sink B-2A Bathroom	126.00	Yes
S013	39-0609-R015	Sink B-2B Bathroom	7.37	No
S014	39-0609-R016	Sink B-2	745.00	Yes
B003	39-0609-R017	Bubbler B-2	2.96	No
S015	39-0609-R018	Sink in 251 Faculty Bathroom	7.74	No
WF001	39-0609-R019	WF in hall outside MPR B	4.19	No
WF002	39-0609-R020	WF inside MPR B	2.15	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: J. Harvey Rodgers School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S016	39-0609-R021	Sink in 241 Faculty Room	1.56	No
WF003	39-0609-R022	WF in Hall outside BSI Room B-1	0.00	No
IM001	39-0609-R023	Ice Machine in Demo Kitchen room 303	4.85	No
S017	39-0609-R024	Sink B-5	18.70	Yes
B004	39-0609-R025	Bubbler B-5	80.30	Yes
S018	39-0609-R026	Sink 239 faculty bathroom	1.64	No
S019	39-0609-R027	Sinks 238 boy bathroom	9.20	No
S020	39-0609-R028	Sink 237 faculty bathroom	2.36	No
WF004	39-0609-R029	WF in Hall outside Room B-7	2.11	No
S021	39-0609-R030	Sinks 235	12.10	No
S022	39-0609-R031	Sink B-8 girl bathroom	3.36	No
B005	39-0609-R032	Bubbler B-8	19.30	Yes
S023	39-0609-R033	Sink B-7	0.00	No
B006	39-0609-R034	Bubbler B-7	5.64	No
S024	39-0609-R035	Sink B-6	0.00	No
B007	39-0609-R036	Bubbler B-6	3.56	No
S025	39-0609-R037	Sink in Demo Kitchen room 303	7.11	No
S026	39-0609-R038	Sink 305	0.00	No
S027	39-0609-R039	Sink A-10	1.26	No
B008	39-0609-R040	Bubbler A-10	0.00	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: J. Harvey Rodgers School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S028	39-0609-R041	Sink A-9	0.00	No
B009	39-0609-R042	Bubbler A-9	0.00	No
S029	39-0609-R043	Sink A-8	16.10	Yes
B010	39-0609-R044	Bubbler A-8	0.00	No
S030	39-0609-R045	Sink A-7	2.77	No
B011	39-0609-R046	Bubbler A-7	0.00	No
S031	39-0609-R047	Sink A-6	1.49	No
B012	39-0609-R048	Bubbler A-6	0.00	No
S032	39-0609-R049	Sink A-5	0.00	No
B013	39-0609-R050	Bubbler A-5	0.00	No
WF005	39-0609-R051	WF in Hall outside A-6	0.00	No
WF006	39-0609-R052	WF in Hall outside A-6	0.00	No
S033	39-0609-R053	Sink 138	0.00	No
S034	39-0609-R054	Sink 139	1.14	No
S035	39-0609-R055	Sink A-4	2.10	No
B014	39-0609-R056	Bubbler A-4	0.00	No
S036	39-0609-R057	Sink A-3	2.09	No
B015	39-0609-R058	Bubbler A-3	5.13	No
S037	39-0609-R059	Sink A-2	0.00	No
B016	39-0609-R060	Bubbler A-2	2.51	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: J. Harvey Rodgers School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S038	39-0609-R061	Sink A-1	1.92	No
B017	39-0609-R062	Bubbler A-1	0.00	No
S039	39-0609-R063	Sink 145 Girl restroom	0.00	No
HB001	39-0609-R064	Hose bib outside 106	11.80	No
S040	39-0609-R065	Sink 147 faculty bathroom	2.71	No
S041	39-0609-R066	Sink 146 boy bathroom	1.00	No
S042	39-0609-R067	Sink 158 bathroom	1.40	No
S043	39-0609-R068	Sink B-1	3.22	No
B018	39-0609-R069	Bubbler B-1	0.00	No
HB002	39-0609-R070	Hose Bib- outside Kitchen Area	1,730	Yes
HB003	39-0609-R071	Hose Bib in courtyard	79.2	Yes
HB004	39-0609-R072	Hose Bib- outside A-8	38.6	Yes
HB005	39-0609-R073	Hose Bib- outside A-10	4.64	No
QC BLANK	39-0609-R074	DI Blank	0.00	No

Action Level (AL) ≥15.5 parts per billion (ppb)  
 ND = None Detected; NR = Not Reported